

Fuel Safety Bulletin

2014-01

Dated: May 20, 2014

Subject: Weil-McLain Boiler Safety Recall

Recently, we have been notified of a possible safety hazard with certain Weil-McLain Ultra series boilers. The affected boilers are Ultra 80, Ultra 105, Ultra 155 and Ultra 230 condensing, high-efficiency gas-fired boilers manufactured after June 1, 2012 and prior to March 11, 2014. The CP number range of the affected boilers is CP 6557046 through CP 6955985.

For more information call Weil-McLain at 888-770-7139 or www.weil-mclain.com/en/weil-mclain/ultragasinfo

For any questions regarding this Bulletin, please contact me at our Halifax offices.

All Fuel Safety Bulletins can be viewed online at: <http://www.gov.ns.ca/lae/fuelsafety/fuelbulletins.asp>

Paul Fowler
Acting Chief Inspector, Fuel Safety