

**Radon testing for the Cape Breton District Health Authority****Draft Summary of results 2007-04-11****Facility: Buchanan Memorial Hospital**

<b>Sample number</b>	<b>Date Analyzed</b>	<b>Electret No.</b>	<b>Test location</b>	<b>Test Resu bec/m3</b>
1	April 4, 2007	SCS713	Room 1059	7.44 bec/m3
2	April 4, 2007	SCS251	Room 1069	26.04 bec/m3
3	April 4, 2007	SCS163	Room 1063	18.6 bec/m3
4	April 4, 2007	SCS150	Room 1065	14.88 bec/m3
5	April 4, 2007	SCH696	Room 1055	40.92 bec/m3
6	April 4, 2007	SCH612	Room 1053	55.8 bec/m3
7	April 4, 2007	SCS256	Nursing Station	14.88 bec/m3
8	April 4, 2007	SCS231	Room 1265	26.04 bec/m3
9	April 4, 2007	SCH 605	Room 1070	55.8 bec/m3
10	April 4, 2007	SCH672	Room 1071	59.52 bec/m3
11	April 4, 2007	ScS159	Room 1267	26.04 bec/m3
12	April 4, 2007	SCS233	Room 1072	14.88 bec/m3
13	April 4, 2007	SCS118	Room 1352	22.32 bec/m3
14	April 4, 2007	SCH607	Room 1100	55.8 bec/m3
15	April 4, 2007	SCH708	Room 1200	40.92 bec/m3
16	April 4, 2007	SCH651	Room 1258	104.16 bec/m3
17	April 4, 2007	SCS196	Room 1255	48.36 bec/m3
18	April 4, 2007	SCS220	Room 1600	66.96 bec/m3
19	April 4, 2007	SCH802	Room 1603	44.64 bec/m3
20	April 4, 2007	SCS116	Room 1605	14.88 bec/m3
21	April 4, 2007	SCH719	Room 1502	59.52 bec/m3
22	April 4, 2007	SCH705	Boiler room	59.52 bec/m3
23	April 4, 2007	SCS213	Room 1559	18.6 bec/m3
24	April 4, 2007	SCS230	Room 1301	78.12 bec/m3
25	April 4, 2007	SCS223	Room 1303	26.04 bec/m3
26	April 4, 2007	SCS125	Room 1067	26.04 bec/m3
27	April 4, 2007	SCS202	Room 1305	29.76 bec/m3
28	April 4, 2007	SCS238	Room 1404	26.04 bec/m3
29	April 4, 2007	SCS165	Room 1151	26.04 bec/m3
30	April 4, 2007	SCH677	Room 1306	37.2 bec/m3

**Radon testing for the Cape Breton District Health Authority****Draft Summary of results 2007-04-11****Facility: Sacred Heart Hospital**

<b>Sample number</b>	<b>Date Analyzed</b>	<b>Electret No.</b>	<b>Test location</b>	<b>Test Result bec/m3</b>
1	April 4, 2007	SCS187	Room 1400	37.2 bec/m3
2	April 4, 2007	SCS266	Room 1419	29.76 bec/m3
3	April 4, 2007	SCR623	Room1416	63.24 bec/m3
4	April 4, 2007	SCS287	Room 1410	14.88 bec/m3
5	April 4, 2007	SCS249	Room 1357	40.92 bec/m3
6	April 4, 2007	SCS242	Room 1412	29.76 bec/m3
7	April 4, 2007	SCS190	Room 1418	40.92 bec/m3
8	April 4, 2007	SCS124	Room 1414	33.48 bec/m3
9	April 4, 2007	SCS148	Room 405	18.6 bec/m3
10	April 4, 2007	SCS226	Room 1403	55.8 bec/m3
11	April 4, 2007	SCS211	Room 11451	14.88 bec/m3
12	April 4, 2007	SCS165	Room 1507	14.88 bec/m3
13	April 4, 2007	SCR625	Room 1552	26.04 bec/m3
14	April 4, 2007	SCS200	Room 1421	26.04 bec/m3
15	April 4, 2007	SCS191	Room 1408	26.04 bec/m3
16	April 4, 2007	SCR489	Room 1352	26.04 bec/m3
17	April 4, 2007	SCS193	Room 1424	48.36 bec/m3
18	April 4, 2007	SCS297	Room 1302	48.36 bec/m3
19	April 4, 2007	SCS247	Room 1251	40.92 bec/m3
20	April 4, 2007	SCS142	Room 1250	33.48 bec/m3
21	April 4, 2007	SCS232	Room 1200	11.16 bec/m3
22	April 4, 2007	SCS149	Room 1254	26.04 bec/m3
23	April 4, 2007	SCS265	Room 1264	29.76 bec/m3
24	April 4, 2007	SCS217	Room 1050	26.04 bec/m3
25	April 4, 2007	SCS290	Reception Area	48.36 bec/m3
26	April 4, 2007	SCS143	Room 1261	40.92 bec/m3
27	April 4, 2007	SCS169	Room 1252	37.2 bec/m3
28	April 4, 2007	SCS271	Room 1658	40.92 bec/m3
29	April 4, 2007	SCS299	Room 1423	18.6 bec/m3
30	April 4, 2007	SCR536	Room 1565	29.76 bec/m3

**Radon testing for the Cape Breton District Health Authority**  
**Draft Summary of results 2007-04-11**  
**Facility:Victoria County Memorial**

Sample number	Date Analyzed	Electret No.	Test location	Test Resu bec/m3
1	April 4, 2007	SCS177	Patient Lounge	14.88 bec/m3
2	April 4, 2007	SCS173	Lab Room	55.88 bec/m3
3	April 4, 2007	SCS218	Public Health Ser.	14.88 bec/m3
4	April 4, 2007	SCS157	Multi Purpose Room	11.16 bec/m3
5	April 4, 2007	SCS164	Reception / Facility manager	26.04 bec/m3
6	April 4, 2007	SCS136	Facility Manager	59.52 bec/m3
7	April 4, 2007	SCS260	Public Health	18.6 bec/m3
8	April 4, 2007	SCS188	Information / Admitting	26.04 bec/m3
9	April 4, 2007	SCS 250	Office behind Reception	26.04 bec/m3
10	April 4, 2007	SCS274	Lab Room	22.32 bec/m3
11	April 4, 2007	SCS240	Film Library	14.88 bec/m3
12	April 4, 2007	SCS203	Examination room #2	3.72 bec/m3
13	April 4, 2007	SCS244	Clerk desk Nurses station	29.76 bec/m3
14	April 4, 2007	SCS189	Conference Room	22.32 bec/m3
15	April 4, 2007	SCS289	In patients # 6	26.04 bec/m3
16	April 4, 2007	SCS291	In patients # 5	26.04 bec/m3
17	April 4, 2007	SCS243	Hospice	29.76 bec/m3
18	April 4, 2007	SCS286	Diabetes room	29.76 bec/m3
19	April 4, 2007	SCS281	Occupational Therapist	33.48 bec/m3
20	April 4, 2007	SCS151	Home care office	22.32 bec/m3
21	April 4, 2007	SCS246	Library	22.32 bec/m3
22	April 4, 2007	SCS212	Physio Room	11.16 bec/m3
23	April 4, 2007	SCS296	Outside kitchen	37.2 bec/m3
24	April 4, 2007	SCS131	Staff lounge	26.04 bec/m3
25	April 4, 2007	SCS280	Maintenance	29.76 bec/m3
26	April 4, 2007	SCS258	Female locker	44.64 bec/m3
27	April 4, 2007	SCS139	Storage / fitness	40.92 bec/m3
28	April 4, 2007	SCS209	Housekeeping	115.32 bec/m3
29	April 4, 2007	SCS175	Stock Room	44.64 bec/m3
30	April 4, 2007	SCS268	Xray	18.6 bec/m3