

**Water Sample Results - General Chemistry and Metals**

Parameter	Units	Canadian Drinking Water Guideline	Detection Limit	Annapolis Royal (062)	
				9-Nov-2005	26-Nov-2007
<b>General Chemistry</b>					
Total Alkalinity (Total as CaCO <sub>3</sub> )	mg/L	-	5	52	54
Chloride (Cl)	mg/L	250 AO	1	6	6
Colour	TCU	15 AO	5	ND	ND
Hardness (CaCO <sub>3</sub> )	mg/L	500 AO	-	43	41
Nitrate + Nitrite	mg/L	10	0.05	ND	ND
Nitrite (N)	mg/L	1	0.01	ND	ND
Nitrate (N)	mg/L	10	0.05	ND	ND
Nitrogen (Ammonia Nitrogen)	mg/L	-	0.05	ND	ND
Total Organic Carbon (C)	mg/L	-	0.5	ND	ND
Orthophosphate (P)	mg/L	-	0.01	0.03	0.02
pH	pH	6.5 - 8.5 AO	-	7.3	8.03
Reactive Silica (SiO <sub>2</sub> )	mg/L	-	0.5	14	12
Sulphate (SO <sub>4</sub> )	mg/L	500 AO	2	7	7
Turbidity	NTU	5 AO	0.1	0.2	<b>15</b>
Conductivity	uS/cm	-	-	130	140
Anion Sum	me/L	-	-	1.38	1.4
Bicarb. Alkalinity (calc. as CaCO <sub>3</sub> )	mg/L	-	1	52	53
Calculated TDS	mg/L	-	1	89	88
Carb. Alkalinity (calc. as CaCO <sub>3</sub> )	mg/L	-	1	ND	ND
Cation Sum	me/L	-	-	1.44	1.42
Ion Balance (% Difference)	%	-	-	2.2	0.71
Langelier Index (@ 20C)	N/A	-	-	-1.15	-0.431
Langelier Index (@ 4C)	N/A	-	-	-1.41	-0.682
Saturation pH (@ 20C)	N/A	-	-	8.45	8.46
Saturation pH (@ 4C)	N/A	-	-	8.71	8.71
Calcium (Ca)	mg/L	-	0.1	15	14
Magnesium (Mg)	mg/L	-	0.1	1.6	1.5
Phosphorus (P)	mg/L	-	0.1	ND	ND
Potassium (K)	mg/L	-	0.1	1	1.2
Sodium (Na)	mg/L	200 AO	0.1	13	13
Bromide (Br)	mg/L	-	0.5	ND	ND
Fluoride (F)	mg/L	1.5	0.1	0.2	0.2
<b>Metals</b>					
Aluminum (Al)	ug/L	-	10	ND	ND
Antimony (Sb)	ug/L	6	2	ND	ND
Arsenic (As)	ug/L	10	2	4	4
Barium (Ba)	ug/L	1000	5	52	66
Beryllium (Be)	ug/L	-	2	ND	ND
Bismuth (Bi)	ug/L	-	2	ND	ND
Boron (B)	ug/L	5000	5	12	12
Cadmium (Cd)	ug/L	5	0.3	ND	ND
Chromium (Cr)	ug/L	50	2	ND	ND
Cobalt (Co)	ug/L	-	1	ND	ND
Copper (Cu)	ug/L	1000 AO	2	ND	ND
Iron (Fe)	ug/L	300 AO	50	ND	ND
Lead (Pb)	ug/L	10	0.5	ND	1
Manganese (Mn)	ug/L	50 AO	2	<b>110</b>	<b>93</b>
Molybdenum (Mo)	ug/L	-	2	4	4
Mercury (Hg)	ug/L	1	0.01		0.02
Nickel (Ni)	ug/L	-	2	ND	ND
Selenium (Se)	ug/L	10	2	ND	ND
Silver (Ag)	ug/L	-	0.5	ND	ND
Strontium (Sr)	ug/L	-	5	59	61
Thallium (Tl)	ug/L	-	0.1	ND	ND
Tin (Sn)	ug/L	-	2	ND	ND
Titanium (Ti)	ug/L	-	2	ND	ND
Uranium (U)	ug/L	20	0.1	1.9	3.6
Vanadium (V)	ug/L	-	2	ND	ND
Zinc (Zn)	ug/L	5000 AO	5	ND	ND

**Notes:**

AO = Aesthetic Objective.

ND = not detected

ND( ) = not detected at the elevated detection limit shown in brackets ( )

All guidelines are health-based MACs or IMACs, unless otherwise indicated.

Shaded values exceed guidelines.